PLUMBING SAFETY Information Bulletin

STANDATA

January 2017

P-09-02-NPC15 Page 1 of 2

SUBJECT: Floor drains and trap seal replenishment

This bulletin has been developed to inform the plumbing industry of the requirements associated with floor drain and trap seal replenishment.

Designers and installers are reminded that careful consideration must be given to the method of maintaining the trap seal and the ability of the owner to maintain it. The National Plumbing Code of Canada 2015 (NPC) Division "B" require provisions be made for maintaining the trap seal of a floor drain by:

2.4.5.5 Trap Seals

- 1) Provision shall be made for maintaining the trap seal of a floor drain by
 - a) The use of the trap seal primer,
 - b) Using the drain as a receptacle for an indirectly connected drinking fountain, or
 - c) Other equally effective means (See Appendix A).

Maintaining a trap seal can be accomplished by periodic automatic replenishment of the water in a trap. Depending on the floor drain size and location, manual replenishment is allowed only in limited residential single family applications. Consider the following:

- Manual replenishment is not considered acceptable where floor drain traps are inaccessible for manual replenishment (residential applications only) after the installation of equipment or appliances. An example is an emergency floor drain in a main floor laundry room.
- A 1 ½ inch indirect waste pipe to a basement floor drain or other suitable location should be used as an alternative for a residential above grade indirect emergency floor drain discharge. Refer to Fig. #1.
- 2 inch floor drains require automatic trap priming.
- The installer should instruct the owner in the procedures for manual replenishment (single family residential) and the correct operation and maintenance of an automatic replenishment system, where applicable.
- 3 inch or 4 inch floor drain trap seals may be automatically replenished with clear water waste from a 1 ½ inch maximum concealed condensate or clear water drain from sources localized to a single mechanical room. The connection may be made on the floor drain fixture outlet pipe under the floor. Refer to Fig. #2.
- Other certified products identified as a floor drain trap seal or trap seal device.

The application of "another effective means" lies with the authority having jurisdiction under Section 1.2 Compliance using "alternate solutions".

Issue of this STANDATA is authorized by the Chief Plumbing Administrator

[Original Signed] Sidney Manning

Alberta Municipal Affairs – Safety Services, 16th Floor, 10155 –102nd Street, Edmonton, Alberta, Canada, T5J 4L4 Phone: 1-866-421-6929 Email: <u>safety.services@gov.ab.ca</u> Website: <u>www.municipalaffairs.alberta.ca</u>



This interpretation is meant as a guide only. Specific site conditions must be considered in each case.

