

Identification of document.

VARIANCE

Date of Issue.

June 14, 2005

Person to Whom the Variance is issued.

Larry Gill, P.Eng.
Manager, Codes and Standards

Address of Person(s) To whom the variance is being issued.

IPEX Inc.
2441 Royal Windsor Drive
Mississauga, Ontario L5J 4C7 Phone: (905) 403-0264

Authority Under which the variance is being issued

Under the authority of the Safety Codes Act, Chapter S-1 section 38(1).

Where the variance applies.

This Variance applies throughout the Province of Alberta.

Details of Variance

Polyethylene/Aluminum/Polyethylene (PE-AL-PE) Composite Pressure Pipe and fittings, certified to **CSA-B137.9** with a pressure rating of 690kpa (100psi) at 82°C (180°F) by a Certification Body is acceptable for hot water installation as part of a plumbing system in Alberta..

This will serve to verify that the installation of IPEX PE/AL/PE piping shall be in accordance with the manufacturer's instructions and the requirements of the National Plumbing Code of Canada (NPC).

This Variance is based on **Sentence 1.4.3(1)** and the proposed revisions to the NPC, which have been supported by the Provincial Territorial Subcommittee on Plumbing Codes (PTSPC), and recently been accepted by the Safety Codes Plumbing Technical Council.

This variance does not make or imply any assurance or guarantee with respect to life expectancy, durability or performance of this material.

Identification of person Issuing the Variance



Signature
Carey LaRose
Plumbing Technical Administrator
Certification No. S 000474

Employer of Administrator

Alberta Municipal Affairs
Plumbing & Gas Safety

Procedure for submission of a variance

A signed copy of the variance will be submitted to:

Safety Codes Council
Suite 800, 10707 - 100 Avenue
Edmonton, Alberta T5J 3M1

Advisement of Offence

Non-Compliance with the instructions contained in this variance is an offence under the Safety Codes Act.

